



# Certificate of Compliance

**Certificate:** 70036216

**Master Contract:** 235284

**Project:** 70057738

**Date Issued:** February 4, 2016

**Issued to:** Huawei Technologies Co., Ltd.  
Huawei Industrial Base  
Bantian Town  
Longgang District  
Shenzhen, 518129  
China  
Attention: Mr. Zhengyou Zhou

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Kyle Song*

**Issued by:** Kyle Song

## **PRODUCTS**

**CLASS 5311 09** - POWER SUPPLIES - Distributed Generation Power Systems Equipment

**CLASS 5311 89** - POWER SUPPLIES - Distributed Generation - Power Systems Equipment  
- Certified to U.S. Standards

Transformerless Utility Interactive Inverter, Models SUN2000-22KTL-US, SUN2000-25KTL-US and SUN2000-30KTL-US, permanently connected.

Notes:

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 107.1-01 - General Use Power Supplies

\*UL Std. No.1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources(January 28, 2010)



**Certificate:** 70036216

**Master Contract:** 235284

**Project:** 70057738

**Date Issued:** February 4, 2016

---

CSA TIL M-07 - Interim Certification Requirements for Photovoltaic (PV) DC Arc-Fault Protection (Issue Number 1, March 11, 2013)

UL 1699B - Outline of Investigation for Photovoltaic (PV) DC Arc-Fault Circuit Protection (Issue Number 2, January 14, 2013)

\*Note: Conformity to UL 1741-Second Edition (January 28, 2010) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547a-2014, IEEE 1547.1-2005(R2011) and IEEE 1547.1a-2015.